

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PR20222818

Address: 451 SE OLDHAM PKWY, Unit:C, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Robb Popp	Failed	Friday, December 30, 2022

Corrective Action Required:

1	Misc	-Connect all grounding electrode conductors to neutral bar -Provide main bonding jumper -Provide address for meter can
---	------	--

Comments: