

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20213548  
Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Robb Popp	Partial	Friday, December 30, 2022

Corrective Action Required:

1	THIRD FLOOR	AREA "A" UNITS AND CORRIDOR APPROVED
		AREA "B" UNITS AND CORRIDOR APPROVED
		AREA "C" UNITS AND CORRIDOR APPROVED
		AREA D UNITS AND CORRIDOR APPROVED

Corrective Action Required:

2	SECOND FLOOR	AREA A UNITS AND CORRIDOR APPROVED
		AREA B UNITS AND CORRIDOR APPROVED
		AREA C UNITS AND CORRIDOR APPROVED

AREA D  
UNITS AND CORRIDOR APPROVED

Corrective Action Required:  
3 FIRST FLOOR

AREA A  
UNITS AND CORRIDOR APPROVED

AREA B  
UNITS AND CORRIDOR APPROVED

AREA C  
UNITS AND CORRIDOR APPROVED

AREA D  
UNITS AND CORRIDOR APPROVED EXCEPT AS NOTED:  
102-NOT READY

Corrective Action Required:  
4 ELEVATOR 1

Corrective Action Required:  
5 STAIR TOWER 1

COMPLETE

Corrective Action Required:  
6 STAIR TOWER 2

COMPLETE

Corrective Action Required:  
7 STAIR TOWER 3

COMPLETE

Corrective Action Required:  
8 STAIR TOWER 4

COMPLETE

**Comments:**