

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20226111  
Address: 1329 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Tuesday, January 03, 2023

Corrective Action Required:

1	Misc	-Protect wiring at bedroom ceiling-wall intersection above light switch -Protect plumbing at bathroom wall under receptacle -The grounding connection at ufer must be accessible
---	------	--

**\*\*OK TO INSULATE**

**Comments:**