

December 21, 2022

Mr. Jeff Boehm, Owner
Zvacek Construction Company
Lee's Summit, Missouri

Re: **Response to Structural Review Comments**
3214 SW Enoch Street, Lee's Summit, Missouri

Jeff,

We have reviewed the condition shown in your photographs and have the following requirements.

1. Hurricane Clips (Simpson A2) at second floor.

This is approved.

2. Truss chord to Ceiling Joist Connection.

This is to provide addition support to Vaulted Ceiling. This is approved, light loading.

If you have any further questions, please ask.

For the Firm,
LORAC Design Group, LLC



Joseph A. Towns, R.A., P.E., SE., AIA, NCARB, LEED AP, BD+C
Missouri Professional Engineer, #E-22017 (Structural)

