

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222195
Address: 4712 NE POCONO CIR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Khanh Nguyen	Failed	Wednesday, January 04, 2023

Corrective Action Required:

1	Misc	-Pool ladder was added after the last pool bonding inspection. Provide verification that the bases were bonded -Bond pool cover motor frame. The rails on both sides of the pool must also be bonded -The gate at rear shall be self-closing and self-latching. The latch shall be located at top of gate -Label all breakers -Where's the pool cover switch? The seitch shall be within sight of the pool.
---	------	---

**FYI: you're not required to ground to earth

Comments: