

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20226242  
Address: 807 SE MILLER ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Wednesday, January 04, 2023

Corrective Action Required:

1	Misc	- Dryer exhaust duct shall have a smooth interior finish and be constructed of metal not less than 0.0157 inch with a 4" diameter. M1502.4.1
		- Install electrical panel
		- Land all electrical wiring
		- Provide combustion air vents, high and low
		- All outlets in living areas must be AFCI protected
		- All electrical to be brought up to 2018 code GFCI's installed were required.
		OK to insulate and rock

Comments: