

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20221592  
Address: 230 SW MAIN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Robb Popp	Failed	Wednesday, January 04, 2023

Corrective Action Required:

1	Misc	-Provide updated plans showing reduction of 2 hour rating to 1 hour rating and UL assemblies -Address rating of existing ceiling spaces below future Reece Nichols space -Complete framing and rock at demising wall RN side for screw pattern inspection
---	------	---

Comments: