

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220956
Address: 520 NE TOWN CENTRE DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Partial	Wednesday, January 04, 2023

Informational:
1 Misc

- 6-30-22 Gordon is installing silt fence
- 7-20-22 AN silt fence is still in good working order
- 8-4-22 AN silt fence is good but need to clan up street
- 9-22-22 AN no work for development
- 9-4-22 AN. No erosion control issues
- 11-30-22 AN no erosion control issues
- 1-5-4-23 DP no erosion control issues

Comments: