

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221422

Address: 3503 SW MARKET ST, LEES SUMMIT, MO 640823505 SW MARKET ST, LEES SUMMIT, MO 640823507
SW MARKET ST, LEES SUMMIT, MO 640823509 SW MARKET ST, LEES SUMMIT, MO
640823501 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Patrick Schonfeldt	Failed	Wednesday, January 04, 2023

Corrective Action Required:

1	Misc	-Upload third party inspection report to permit -Permanent address labels on disconnects and meter cans -GFCI protections at outlets in mechanical room -Provide schedule for all breaker locations at house panel -Secure MC at mech room -Label all RTU units on roof
---	------	--

***SEE FIRE, PLANNING, WATER AND ENGINEERING GROUP INSPECTION
REPORTS FOR THOSE DEPT CORRECTIONS

Comments: