

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213681
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Thursday, January 05, 2023

Corrective Action Required:

1 Misc

***Pre Final units only

1st Floor:

A

—Throughout:

ADDRESS EXTERIOR LIGHTING PER SECURITY CODE

141-Repair rated assembly at ceiling and stairwell

B

148-Clarify unit type A or B for accessible unit, provide adjustable height hand shower

2ND FLOOR:

A

-OK

B

-OK

3rd Floor

A
-OK

B
347-anti tip device at range

C
355-Correct collar at hvac
354-Anti tip device at range, correct collar at hvac, seal penetration, exterior
GFCI
356-Seal hvac penetration

Comments: