



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20110540, Building Permit - Commercial  
Address: 2810 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	John Borns	Passed	Monday, May 09, 2011

**Comments: WALL FRAMING AND IN-WALL SYSTEMS OK TO COVER WHEN READY AFTER ALL JAMB STUDS ARE SCREWED BOTH FLANGES AT BASE TRACK. ENSURE BLOCKING IS IN PLACE FOR THREE GRAB BARS AT SPACES 105 & 106.**