

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220089
Address: 4417 SW GRINDSTONE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Not Ready	Friday, January 06, 2023

Corrective Action Required:

1	Misc	-final grade and sod -splash blocks -Tamper resistant outlets required per code IRC E4002.14, NEC 406.12(A) -GFCI protection required at dishwasher outlet -master bath GFCI outlet tripping when energized -AFCI protection all circuits per code IRC E3902.16 NEC 210.12(A) -secure exterior light fixtures at garage and seal along top of fixture -secure electrical whip within 12" of disconnect at AC -tamper resistant valve caps required at AC -seal along top of AC disconnect
---	------	--

Comments: