

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222664
Address: 904 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection	Eric Sharp	Failed	Friday, January 06, 2023

Corrective Action Required:

1	Miscellaneous Correction	1-6-23 DP. Meter pit needs to be replaced and moved. The meter also needs to be raised to 14-18" from top of meter to bottom of lid.
---	--------------------------	--

Comments: