

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20215272

Address: 3679 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643679 NE AKIN DR, Unit:C, LEES SUMMIT, MO  
640643679 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643679 NE AKIN DR, Unit:A, LEES  
SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Khanh Nguyen	Partial	Monday, January 09, 2023

Corrective Action Required:

1	Misc	Attic separation wall-2nd layer ok
		Dwelling firewall- 1st layer ok
		**provide 2 layers of fire rock at attic separation wall above garage (B unit) ; close hole

**Comments:**