

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220956

Address: 520 NE TOWN CENTRE DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hydrant Inspection	Adam Nacke	Failed	Monday, January 09, 2023

Corrective Action Required:

1	Misc	1-9-22 DP all private fire hydrants need to have a silver painted bonnet.
---	------	---

Corrective Action Required:

2	Miscellaneous Correction
---	-----------------------------

Comments: