

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221052
Address: 3206 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, January 09, 2023

Corrective Action Required:

1	Misc	-fire block into furr down in garage(see hvac and dwv chases) -provide minimum 10 psi at gauge for gas test -provide proper anchoring for cspf refer to figure r602.10.6.4 of the 2018 irc
---	------	--

Comments: