

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214608

Address: 916 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081918 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081920 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081922 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081924 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081926 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081928 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081914 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Monday, January 09, 2023

Corrective Action Required:

1	Misc	1/9/23 -Partial inspection only
---	------	------------------------------------

Throughout:

- Provide all addresses
- Complete final grade/ sod
- Provide downspout extensions/ foundation drainage 36" away from foundation
- All receptacles in laundry areas to be GFCI
- Provide dedicated non gfci receptacle under sink
- Secure all mc under sink in island within 12" of boxes
- Provide access to rooftop for inspection

914-Complete throughout items, connect dishwasher discharge hose, secure receptacle at laundry, bad GFCI at washer

916-Bad GFCI at 1st floor bath

918-Secondary lock at SGD

Comments: