

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225303
Address: 901 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|---------------------------|
| Footing Inspection - Commercial | Robb Popp | Failed | Tuesday, January 10, 2023 |

Informational:

1 Misc

The following areas are approved:

-Line B footing complete
-Line 3 Footing complete

Corrective Action Required:

2 Misc

-1/10/23
-PROVIDE 3" CLEARANCE TO EARTH AT REMAINING FOOTINGS AND AT ALL INTERIOR PIER PADS

Comments: