

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215491
Address: 1604 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, January 11, 2023

Corrective Action Required:

1	Misc	-sod -splash blocks and sump pump discharge to extend 36" from foundation -safety glazing at master window near read patio door -hand rail in garage to be code compliant see code section 311.7.8.5 -tamper caps at a/c unit -seal all exterior penetrations
---	------	--

Comments: