

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216094
Address: 2602 SW FARM FIELD RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, January 12, 2023

Corrective Action Required:

1 Misc

- anchor bolts to be in the middle 1/3 of sill plate (see pfh)NOT DONE
- over notched double joists above owners bath(fix to engineer specifications to be full length) waiting on updated letter
- Provide anchor bolts for short return wall basement south side (2 required)

OKAY TO INSULATE

Comments: