

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225301
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer Construction Inspection	John Jackson	Partial	Thursday, January 12, 2023

Informational:

1	Misc	12/27/22 Tuesday (She Digs It SDI) Contractor installing MH A1 @STA 3+23.74 4' sanitary sewer doghouse manhole see detail 706, C790-C.
		01/12/23 Thursday (SDI) Contract removing abandoned gas main so they can continued the installation of 8" sanitary main.

Comments: