

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213720
Address: 4713 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, January 13, 2023

Corrective Action Required:

1	Misc	-Move the smoke alarm min 4" away from wall -Extend return air to ceiling level of bedroom -Cannot supply the receptacle inside mechanical space from bath receptacle circuit
---	------	---

Comments: