

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20221592  
Address: 230 SW MAIN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Fire Line - Hydrostatic Test</b>	John Jackson	Passed	Friday, January 13, 2023

Informational:  
1 Misc 01/13/23 Friday JMJ ( ESS- Steve )  
2 Hour Fire line hydrostatic test pass @11:00AM

**Comments:**