CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20216183Address:2804 SW HEARTHSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspect	tion:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential		Mitchell Schwarz	Failed	Tuesday, January 17, 2023
Correct	ive Action Required:			
1	Misc	EROSION CONTROL TO REMAIN IN COMPLIANCE UNTIL SOD IN PLACE NO FURTHER INSPECTIONS UNTIL EROSION CONTROL IS IN COMPLIANCE -sod		
		splash blocks and sump pump discharge to extend 36" from foundation identified sewer tracer wire		
		-lable all non GFCI protected outlets in unfinished spaces. -security screws at rear patio door		

Comments: