CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216029

Address: 1601 SW ARBORWAY TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Mitchell Schwarz Failed Tuesday, January 17,

Residential 2023

Corrective Action Required:

1 Misc -pay all fees

-address pending sidewalk inspection

-splash blocks and sump pump discharge to extend 36" from foundation

-outlet in entry bath not working

-outlets in garage to be GFCI protected

If not GFCI protected to be single receptacle and labeled -office and master afci protection at breaker panel -lockouts for all hardwired appliances at panel

-spark ring at kitchen and wet bar outlets where as required by code

-stairs at rear patio greater than 3/8" difference

-spark ring above fireplace -smoke detectors dead battery

Comments: