

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223554
Address: 196 SW WINTER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Shawn Hoffman	Partial	Tuesday, January 17, 2023

Corrective Action Required:

1	Misc	Bonding to 4 points to re-bar on shell 2 points of bonding on hot tub shell only - 1/17/23 bonded to grid for apron OK - make sure binding accessible for cover motor and rails
---	------	--

OK to pour apron

This is a partial inspection, schedule again when water bond, bonding ring, accessories, power cover, pumps are bonded.

Comments: