

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220082
Address: 3205 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, January 17, 2023

Corrective Action Required:

1	Misc	-address pending sidewalk inspection -pay all fees -spark ring for outlet above fireplace -outlets under sink not working -security screws at rear door 2 per hinge -garage door to be self closing and latching -outlets in garage to comply with code section E3901.9 -handrail in garage to be code compliant R311.7.8.5
---	------	--

Comments: