

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20224010
Address: 3509 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Patrick Schonfeldt	Partial	Tuesday, January 17, 2023

Corrective Action Required:

1	Misc	FOLLOWING AREAS ABOVE CEILING APPROVED
		11/30/22 HARD LIDS 103,122,119
		12/2/22 HARD LID LOBBY 101
		-Fire caulk penetrations at firewall
		-Secure MC within 12" of box at corridor walls
		-Knockout cover in corridor
		 **OK for tile in other locations

Comments: