

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

Permit #: PRRES20213746  
Address: 725 SW 15TH CIR, LEES SUMMIT, MO 64081  
Inspected On: Tuesday, January 17, 2023  
Inspected By: Robb Popp  
Expiration Date: 2/16/2023 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Pending	

Corrective Action Required:

- |   |      |  |
|---|------|--|
| 1 | Misc | -address pending pier inspection, piers poured without inspection<br>-final grade and sod<br>-check water meter depth and grade at time of final sod and grade meter to be 14"-18" from meter top to well lid<br>-missing nails in joist hangers at deck |
|---|------|--|