

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215279
Address: 3663 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643663 NE AKIN DR, Unit:C, LEES SUMMIT, MO 640643663 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643663 NE AKIN DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Partial	Wednesday, January 18, 2023

Corrective Action Required:

1	Misc	Attic separation wall-2nd layer ok
---	------	------------------------------------

Dwelling firewall-1st layer ok

*firecaulk membrane penetrations of attic firewall; 2 layers at garage attic fw wood blocks

Comments: