

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215236
Address: 1521 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, January 18, 2023

Corrective Action Required:

1	Misc	-pay all fees -hardware at rear patio door -security screws at rear door -future vent for future basement bath -water meter to be 14"-18" from top of meter to well lid -splash blocks and sump pump discharge to extend 36" from foundation
---	------	---

Comments: