

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215093
Address: 1533 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, January 18, 2023

Corrective Action Required:

1	Misc	-pay all fees -bring water meter to grade. Maintain 14"-18" from meter top to to well lid ring -guard rail at front stoop where required by code -outlets for counter top space right and left of fireplace -attic access cover in garage -provide proper access to mechanical and electrical for spa tub in master see E4209.4 and P2720.1
---	------	--

Comments: