

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20221422

Address: 3503 SW MARKET ST, LEES SUMMIT, MO 640823505 SW MARKET ST, LEES SUMMIT, MO  
640823507 SW MARKET ST, LEES SUMMIT, MO 640823509 SW MARKET ST, LEES  
SUMMIT, MO 640823501 SW MARKET ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Planning</b>	Shannon McGuire	Temporary C of O	Wednesday, January 04, 2023

Corrective Action Required:

1

All exterior trash enclosure gates must be constructed of a solid steel opaque gate painted to be compatible with the color of the masonry or steel walls and building it is to serve or a steel framed semi-opaque gate with a screen mesh material

Corrective Action Required:

2

Wall-mounted lights shall utilize full cut-off fixtures. The wall lights on the sides and rear of the building must be replaced with lights with full cut-off fixtures.

**Comments:**