CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20220181Address:1713 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:	
Occupancy Inspection - Code Residential	s Mitchell Schwarz	Failed	Wednesday, January 18, 2023	
Corrective Action Required:				
1 Misc	MAINTAIN EROSION CONTROL			
	-outlet at counter top -open junction box rig -bath fan switch in ma -open junction box's a -ensure basement sta -anti syphon device at	final grade and sod check water meter at time of final grade and sod outlet at counter top left of fireplace open junction box right of cook top bath fan switch in master open junction box's above 2nd floor bedrooms ensure basement stairs meet code R311.7.2 for headroom anti syphon device at basement water spigot open electrical at entry bath		

Comments: