

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225202
Address: 880 NW BLUE PKWY, Unit:H, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Failed	Wednesday, January 18, 2023

Informational:

1	Misc	-HARD LIDS AT ENTRY AND CORRIDOR OK
---	------	-------------------------------------

Corrective Action Required:

2	Miscellaneous Correction	-Secure all mc per code -Support all wiring off of grid -Provide knockout covers at all openings in boxes -Land lv connecitons inside of box or fixture
---	-----------------------------	--

Comments: