

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20216183
Address: 2804 SW HEARTHSTONE PL, LEES SUMMIT, MO 64082
Inspected On: Wednesday, January 18, 2023
Inspected By: Mitchell Schwarz
Expiration Date: 2/17/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Pending	

Corrective Action Required:

1	Misc	EROSION CONTROL TO REMAIN IN COMPLIANCE UNTIL SOD IN PLACE NO FURTHER INSPECTIONS UNTIL EROSION CONTROL IS IN COMPLIANCE -sod -splash blocks and sump pump discharge to extend 36" from foundation
---	------	---