

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED**

---

**Permit #:** PRRES20224609  
**Address:** 508 SE CARTER RD, LEES SUMMIT, MO 64082

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection: Inspector: Outcome: Date:

**Underslab Plumbing** Mitchell Schwarz Pending  
**Inspection - Residential**

Corrective Action Required  
1 Misc

INSPECTION DENIED

-POST ADDRESS  
-MAINTAIN EROSION CONTROL

Corrective Action Required  
2 Misc

underslab plumbing covered without inspection.  
Mitchell Schwarz 01/18/2023 1:34 PM

**Comments:**