

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222242
Address: 530 NE TOWN CENTRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Commercial	Khanh Nguyen	Failed	Wednesday, January 18, 2023

Corrective Action Required:

1 Misc

GAS PIPING SYSTEM IS NOT PER APPROVED PLAN. SUBMIT REVISED PLAN TO THE CITY FOR APPROVAL

1/18/23-THE GAS PIPING SIZE DOES NOT SEEM TO BE COMPLIANT WITH THE PLAN (1-1/4" TRANSITION RISER AT NORTH END); THE PLAN STILL SHOWS THE ABOVE-GROUND GAS PIPING; INSTALL TRACER WIRE PER CODE.

****PRESSURE TEST HOLDS**

Comments: