

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220426  
Address: 102 SW 2ND ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Thursday, January 19, 2023

Corrective Action Required:

1	Misc	-Stair risers at exterior to be within 3/8" variance
---	------	------------------------------------------------------

**\*\*1/19/23** TCO has expired. Emailed and called contractor on 1/18/23 with no replies. Permit has been placed in NOV status. R. Popp

**Comments:**