

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215283

Address: 3647 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643647 NE AKIN DR, Unit:C, LEES SUMMIT, MO
640643647 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643647 NE AKIN DR, Unit:E, LEES
SUMMIT, MO 640643647 NE AKIN DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Failed	Thursday, January 19, 2023

Corrective Action Required:

1 Misc

UNIT A:

-Fully nail stud shoe

UNIT B:

-Support vent in attic per code

-Roof leak at 3" vent roof flashing above rear bathroom

UNIT C:

-Support plumbing above kitchen

-Support vent in attic per code

UNIT D:

-Support plumbing above kitchen

-Support vent in attic per code

UNIT E:

****OK TO INSULATE**

Comments: