

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222875
Address: 365 NW PATCH CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Thursday, January 19, 2023

Corrective Action Required:

1	Misc	- Address 6x6 deck post not continuous per plan { not installed to engineers letter on 10/18/22)
---	------	--

10/19/22 - ENGINEER LETTER STATES FOR 24" CS-16 STRAP CENTERED AT SPLICE FOR NON CONTINUOUS POST REPAIR

- Final grading and sod
- Provide splash blocks
- Seal gaps at attic access in garage
- Steps at garage entry over allowed variance of 3/8'

Comments: