

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221673
Address: 2609 SW HOOK FARM LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, January 19, 2023

Corrective Action Required:

1 Misc

- pay all fees
- address pending sidewalk inspection
- final grade and sod
- check water meter at time of final grade and sod
- splash blocks and sump pump discharge to extend 36" from foundation
- GFCI receptacle in garage not working
- outlets in bathrooms not working
- lock out for water heater breaker
- GFCI protection for dishwasher
- outdoor outlets not working

Comments: