

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220895

Address: 1061 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811063 NW BLACK TWIG CIR, LEES SUMMIT, MO  
640811065 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811059 NW BLACK TWIG CIR,  
LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Robb Popp	Failed	Thursday, January 19, 2023

Corrective Action Required:

1	Misc	Land electrical at all bath fans, provide bonding screw and jumper at all metallic boxes at all units
---	------	---

In addition:

1063-Provide anchor bolts rear exterior wall both sides of sgdr, land electrical upstairs bath ceilings, support dwv 4' oc in attic space bath 2

1059-seal penetrations and protect dryer.

**Comments:**