

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20221806  
Address: 3208 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Friday, January 20, 2023

Corrective Action Required:

1 Misc

- 5 studs each end per plans in garage un gt truss
- anchor bolts to be in the middle 1/3 of sill plate in garage
- fire block dead spaces to ceiling space at garage entry. (When using Unfaced insulation must be packed tightly and securely)
- completely furr out for laundry wall and fire block if necessary
- fire block fireplace wall to ceiling space
- use correct hangers for 2x8's above great room
- frame great room windows wall to plans
- missing studs under lvl above entry at stairs
- entry framing does not match plans
- missing steel column A at stairs

**Comments:**