

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222650
Address: 4809 NE FREEHOLD CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Khanh Nguyen	Failed	Friday, January 20, 2023

Corrective Action Required:

1	Misc	-Install a #4 cu bonding jumper from the equivalent grounding bus bar where the GEC is connected to, to the grounded bus bar in middle -The grounding clamp to rebar is listed for rebar application? Tight connection?
---	------	--

Comments: