

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20222753  
Address: 2226 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Friday, January 20, 2023

Corrective Action Required:

1	Misc	Fb top plate penetrations garage wall at stairs - Collar ties garage roof - Address deck post splice not to plan - No overlap entry wall and dining room wall at top plate - Joist hangers missing nails hall near owner suite - No overlap at top plate owners bedroom and sliding door wall - Stud shoes in owner bathroom should have nails or structural screws and missing a few - 3 studs minimum exterior corner basement bedroom 3 - No water line to hose bib near sump discharge
---	------	--

Comments: