

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20222707  
Address: 300 SW NOEL ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Friday, January 20, 2023

Corrective Action Required:

1	Misc	-Provide accessible route complying with IBC 1104 and 2017 A117.1 chapter 4 from lower level per plan **Have design professional address accessible route from this space as exostomg ramp is currently non code compliant
---	------	---

Informational:

2	Misc	1/20/23 Partial occupancy for lower level only -Interior inspected and approved but not approved for occupancy or use until accessible route is addressed
---	------	---

Comments: