

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220590
Address: 520 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	John Jackson	Failed	Friday, January 20, 2023

Corrective Action Required:

1	Misc	01/20/23 Friday JMJ (Remas) ADA ramps on the and the walkway through the approach failed. So, the West ramp, East ramp, walkway between need to be torn out and re-installed to specifications.
---	------	---

Comments: