

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20220902
Address: 520 NE TOWN CENTRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------|------------|----------|--------------------------|
| Water Line - Coliform Test 1 | Adam Nacke | Passed | Monday, January 23, 2023 |

Informational:
1 Misc 1-9-23 DP. Crew never opened up valve after samples passed so they need to flush again and take 1 more sample
1-23-23 DP Took water sample and passed. Valve is opened.

Comments: