

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213681
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Planning	Hector Soto Jr.	Temporary C of O	Monday, January 23, 2023

Corrective Action Required:	
1 Misc	Complete parking lot lighting installation per approved plan.
Corrective Action Required:	
2 Misc	Complete landscaping per approved plan.
Corrective Action Required:	
3 Misc	Install ADA parking space signs at the head of each space (in landscape area) per the approved plans.

Comments: